


Annual Report

Hudson Drinking Water System

2022

Prepared by **Northern Waterworks Inc.**
on behalf of the **Municipality of Sioux Lookout**



Contents

1	Introduction	3
1.1	Annual Reporting Requirements	3
1.2	Report Availability	3
2	System Overview & Expenses	4
2.1	System Description	4
2.2	Water Treatment Chemicals	5
2.3	System Expenses	6
3	Water Quality.....	7
3.1	Overview	7
3.2	Microbiological Parameters	7
3.3	Operational Parameters	8
3.4	Conventional Filtration & UV Disinfection Performance	9
3.5	Nitrate & Nitrite	10
3.6	Trihalomethanes & Haloacetic Acids	10
3.7	Environmental Discharge Sampling.....	11
3.8	Lead Sampling.....	12
3.9	Inorganic & Organic Parameters	13
3.10	Harmful Algae Bloom Monitoring	15
4	Water Production.....	15
4.1	Overview	15
4.2	Flow Monitoring Results	15
4.3	Recent Historical Flows.....	17
5	Compliance	18
5.1	Overview	18
5.2	Regulatory Compliance	19
5.3	Adverse Water Quality Incidents	19

1 Introduction

1.1 Annual Reporting Requirements

This consolidated Annual Report (the Report) has been prepared in accordance with both section 11 (Annual Reports) and Schedule 22 (Summary Reports for Municipalities) of Ontario Regulation 170/03 (Drinking Water Systems Regulation). This Report is intended to inform both the public and Municipal Council about the operation of the system over the previous calendar year (January 1 to December 31, 2022).

Section 11 of O. Reg. 170/03 requires the development and distribution to the public of an annual report summarizing water quality monitoring results, adverse water quality incidents, system expenses and chemicals used in the water treatment process. Schedule 22 of O. Reg. 170/03 requires the development and distribution to Council of an annual report summarizing incidents of regulatory non-compliance and associated corrective actions, in addition to providing flow monitoring results for the purpose of enabling the Owner to assess the capability of the system to meet existing and planned demand.

1.2 Report Availability

In accordance with section 11 of O. Reg. 170/03, this Report must be given, without charge, to every person who requests a copy. Effective steps must also be taken to advise users of water from the system that copies of the report are available, without charge, and of how a copy may be obtained. This Annual Report shall be made available for inspection by the public at the Municipal Office in Sioux Lookout, at the Lost Lake Seniors Drop-In Centre in Hudson and on the Municipality's website.

In accordance with Schedule 22 of O. Reg. 170/03, this Annual Report must be given to the members of Municipal Council. Section 19 (Standard of care, municipal drinking-water system) of Ontario's *Safe Drinking Water Act* (SDWA) also places certain responsibilities upon those municipal officials who oversee an accredited operating authority or exercise decision-making authority over a system. The examination of this Report is one of the methods by which municipal officials may fulfil the obligations required by section 19 of the SDWA.

System users and members of Council should contact a representative of NWI for assistance in interpreting this Report. Questions and comments may be directed to the local NWI Operations Manager or by email to compliance@nwi.ca.

2 System Overview & Expenses

2.1 System Description

The Hudson Drinking Water System must meet extensive treatment and testing requirements to ensure that human health is protected. The operation and maintenance of the system is governed by Ontario's *Safe Drinking Water Act* and the regulations therein, in addition to requirements within system-specific environmental approvals. Important system information is summarized in Table 1.

Table 1: System information	
Drinking-Water System Name:	Hudson Drinking Water System
DWS Number:	220005385
DWS Category:	Large Municipal Residential
DWS Owner:	The Corporation of the Municipality of Sioux Lookout
DWS Operating Authority:	Northern Waterworks Inc.
DWS Components:	<ul style="list-style-type: none">• Raw water pumping station• Hudson Water Treatment Plant• Hudson water distribution system
Treatment Processes:	<ul style="list-style-type: none">• Chemical coagulation, flocculation and clarification• Dual media (rapid sand) filtration• Ultraviolet disinfection (primary disinfection)• Free chlorine disinfection (secondary disinfection)• pH adjustment

Water production begins as raw water flows by gravity from the intake structure located in Lost Lake to an underground reservoir located at the raw water pumping station. Pumps then transfer water from the reservoir and through a short transmission line to the treatment units at the water treatment plant. At the Hudson Water Treatment Plant, polyaluminum chloride (coagulant) is injected and rapidly mixed into the raw water immediately upstream from the package treatment units. Coagulated water enters two treatment units each including a three-chambered flocculation basin, a clarifier and filter.

Water is gently mixed as it passes through the flocculation basins to promote floc formation, and the optional application of polymer (flocculant) at this stage of treatment is intended to form larger floc aggregates. Process water then enters the clarifier where its velocity is reduced to allow for the separation and settling of floc. Supernatant overflows into the clarifier effluent launders and is directed to the filter; settled floc is automatically removed from the clarifier.

Impurities that were not captured and settled as floc in the clarifier are removed by passing water through a dual media filter composed of anthracite and silica sand on a layer of support gravel. The filters are periodically cleaned by using an air scour to agitate the entire media bed and reversing the flow of water through the filter using dedicated pumps. Sodium metabisulfite may be used as required to dechlorinate the treated water that is used clean the filters.

Filtered water then passes through one of two available UV reactors for disinfection as it is directed to the treated water storage reservoir. Prior to entering the reservoir, chlorine and sodium hydroxide are applied to the filtrate for secondary disinfection and pH adjustment purposes, respectively. Disinfected water is stored in the reservoir and is transferred to the Hudson water distribution system using pumps.

The Hudson water distribution system was installed exclusively in 1990 and includes approximately 6 km of water mains, 46 valves and 7 hydrants. Watermain materials consist of HDPE and PVC ranging in size from 50 to 150 mm in diameter. Secondary disinfection requirements are achieved by maintaining a free chlorine residual at all locations.

2.2 Water Treatment Chemicals

In accordance with section 11 of O. Reg. 170/03, this Report must include a list of all water treatment chemicals used by the system during the period covered by the report (summarized in Table 2). All chemicals used in the treatment process are NSF/ANSI 60 certified for use in potable water, as required by system approvals.

Table 2: Water treatment chemicals used in 2021


Treatment Chemical	Application
polyaluminum chloride	coagulant
sodium hydroxide	pH/alkalinity adjustment
chlorine gas	secondary disinfectant

2.3 System Expenses

In accordance with section 11 of O. Reg. 170/03, this Report must describe any major expenses incurred during the reporting period to install, repair or replace required equipment. This Report also summarizes those expenses related to strengthening equipment inventories and to maintenance activities undertaken by subcontracted service providers. Major expenses incurred in 2022 are summarized in Table 3.

Table 3: Major expenses incurred in 2022

Category	Description	Expense
Replacement	SCADA Computer	\$5,598
Replacement	Chemical feed pump flow monitoring switches	\$4,003
Replacement	UV bulbs (8) replacement	\$3,692
Replacement	Chlorine analyzer probe	\$4,780
Maintenance	Annual backflow preventer inspections	\$817
Maintenance	Annual flow meter verifications	\$1,300
Maintenance	Annual SCADA programming	\$2,776



3 Water Quality

3.1 Overview

Water quality monitoring is conducted to determine and confirm that drinking water delivered to the consumer is safe and aesthetically pleasing. Monitoring is also required to assess compliance with legislation and to control the treatment process. In accordance with section 11 of O. Reg. 170/03, this Report must summarize the results of water quality tests required by regulations, approvals, and orders. The following sections summarize the results of all required water quality tests and compare the results to applicable water quality standards.

3.2 Microbiological Parameters

Microbiological sampling and testing requirements are provided in Schedule 10 (Microbiological sampling and testing) of O. Reg. 170/03. In 2022, a total of 255 routine source, treated and distribution water samples were collected for microbiological analysis by an accredited laboratory. Samples were collected on a weekly basis and included tests for E. coli (EC), total coliforms (TC) and heterotrophic plate counts (HPC). Results from microbiological analyses are summarized in Table 4. All results were below the associated Ontario Drinking Water Quality Standards.

Table 4: Results summary for microbiological parameters

Sample Type	# of Samples	EC Results Range ¹ (MPN/ 100mL)	TC Results Range ¹ (MPN/ 100mL)	# of HPC Samples	HPC Results Range (CFU/mL)
Raw Water	51 ²	0 to 2	0 to 770	---	---
Treated Water	51 ²	absent	absent	51 ²	0 to 78
Distribution	153	absent	absent	102	0 to 3

1. The Ontario Drinking Water Quality Standard for E. Coli and Total Coliforms in a treated or distribution sample is 'not detectable'. The presence of either parameter in a treated or distribution sample is considered an exceedance.
2. One weekly raw and treated sample was not received at the lab in time to be tested. Notification was provided to the MECP and no further action was required.

3.3 Operational Parameters

In accordance with Schedule 7 (Operational checks) of O. Reg. 170/03, regulated operational parameters that must be monitored include raw water turbidity, filtrate turbidity and the free chlorine residual associated with secondary disinfection. In accordance with the system's *Municipal Drinking Water Licence*, additional parameters that must be monitored include treated water pH and alkalinity. Table 5 summarizes water quality results for regulated and selected unregulated operational parameters. In accordance with Schedule 6 (Operational checks, sampling and testing – general) of O. Reg. 170/03, certain operational parameters are continuously monitored. No Adverse Water Quality Incidents (AWQIs) pertaining to operational parameters occurred during the reporting period.

Table 5: Results summary for operational parameters

Parameter (Sample Type)	No. of Samples	Units	Min. Result	Max. Result	Annual Avg.	Adverse Result
Turbidity (Raw Water)	53	NTU	0.23	3.77	1.12	n/a
Turbidity (Filter 1)	Continuous	NTU	0.011	0.550	0.023	>1.0
Turbidity (Filter 2)	Continuous	NTU	0.011	0.560	0.026	>1.0
Turbidity (Treated)	364	NTU	0.021	0.510	0.113	n/a
pH (Treated)	Continuous	---	6.50	8.22	7.82	n/a
Alkalinity (Treated)	155	mg/L	35	55	47	n/a
Aluminum Residual (Treated)	52	mg/L	0.002	0.085	0.036	n/a
FCR ² (Treated)	Continuous	mg/L	0.08	1.79	1.04	n/a
FCR ² (Distribution) ³	470+	mg/L	0.41	1.74	n/a	<0.05

1. FCR = free chlorine residual.
2. Free chlorine residuals are tested at various locations in the distribution system. The free chlorine residual varies with water age and distribution system location, and the values in the table pertain to the minimum and maximum results collected across all locations in the calendar year.

3.4 Conventional Filtration & UV Disinfection Performance

In accordance with the system's *Municipal Drinking Water Licence*, the conventional filtration process must meet certain performance criteria in order to claim removal credits for *Cryptosporidium* oocysts and *Giardia* cysts. In addition to continuously monitoring filtrate turbidity and other requirements, filtrate turbidity must be less than or equal to 0.3 NTU in at least 95% of the measurements each month. Table 6 summarizes filtrate turbidity compliance against the <0.3 NTU/95% performance criterion. Minimum and maximum values in the table correspond to the proportion of time that filtered water turbidity was less than or equal to 0.3 NTU in a calendar month in 2022. No Adverse Water Quality Incidents (AWQIs) pertaining to conventional filtration performance occurred during the reporting period.

Table 6: Filtration performance summary

Filter	Minimum Result	Maximum Result	Adverse Result
Filter 1	100%	100%	<95%
Filter 2	100%	100%	<95%

To ensure primary disinfection, the UV reactors at the facility must operate within their validated operating conditions to achieve a minimum continuous pass-through UV dose of 40 mJ/cm². The dose is a function of the flow through the reactors, the applied UV intensity and the UV transmittance (purity) of the filtrate. The reactors are considered to be operating “off-specification” any time when conditions are below a minimum UV intensity, below a minimum UV transmittance or above a maximum flow rate for more than 2 minutes. Table 7 summarizes UV equipment performance against the validated operating conditions. An off-specification event is classified as an AWQI if UV equipment operates outside of the validated range for a continuous period of 10 minutes. There was one (1) AWQI with respect to the UV system in 2022. Refer to Section 5.3 for details of the event.

Table 7: UV disinfection performance summary

Parameter	No. of Samples	Units	Min. Result	Max. Result	Annual Avg.	Adverse Result
Flow (Combined Filtrate)	Continuous	L/s	n/a	6.49	5.61	>9.3
UV Intensity (Reactor 1)	Continuous	W/m ²	0.0 ¹	n/a	71.8	<50.6
UV Intensity (Reactor 2)	Continuous	W/m ²	0.0 ¹	n/a	76.7	<50.6
UV Transmittance (Filter 1)	52	%/1cm	87.5	92.1	90.5	<85.1
UV Transmittance (Filter 2)	52	%/1cm	87.9	92.9	90.6	<85.1

1 – AWQI for this was completed on November 29, 2022

3.5 Nitrate & Nitrite

Treated water is tested for nitrate and nitrite concentrations on a quarterly basis in accordance with Schedule 13 (Chemical sampling and testing) of O. Reg. 170/03. Nitrate and nitrite results

Table 8: Nitrate and nitrite results

Sample Date	Nitrate		Nitrite	
	Result (mg/L)	ODWQS (mg/L)	Result (mg/L)	ODWQS (mg/L)
15-Feb-2022	0.082	10	<0.010	1
17-May-2022	0.711		<0.010	
16-Aug-2022	0.027		<0.010	
15-Nov-2022	0.035		<0.010	

are provided in Table 8. All results were below the Ontario Drinking Water Quality Standards.

3.6 Trihalomethanes & Haloacetic Acids

Trihalomethanes (THMs) and haloacetic acids (HAAs) are sampled on a quarterly basis from a distribution system location that is likely to have an elevated potential for their formation, in accordance with Schedule 13 (Chemical sampling and testing) of O. Reg. 170/03. Total THM and HAA results are provided in Table 9 and Table 10, respectively. Compliance with the provincial standards for trihalomethane and haloacetic acid concentrations is determined by calculating a running annual average (RAA). The 2022 running annual averages for THMs and HAAs were below the respective Ontario Drinking Water Quality Standards.

Table 9: Total THM results

Sample Date	Result (µg/L)
15-Feb-2022	58.7
17-May-2022	46.2
16-Aug-2022	84.1
15-Nov-2022	80
Regulatory Average (RAA)	63.7
ODWQS (RAA)	100

Table 10: Total HAA results


Sample Date	Result (µg/L)
15-Feb-2022	73.7
17-May-2022	45.4
16-Aug-2022	72.3
15-Nov-2022	69.2
Regulatory Average (RAA)	65.2
ODWQS (RAA)	80

3.7 Environmental Discharge Sampling

The *Municipal Drinking Water Licence* for the Hudson Drinking Water System requires sampling associated with discharges to the natural environment. Specifically, samples must be collected from settling tank effluent on a quarterly basis and tested for the parameter total suspended solids (TSS). This effluent is discharged to a disbursement field which has been designed for the management of residues produced during the normal operation of the treatment facility. Environmental discharge sampling results are provided in Table 11.

Table 11: Environmental discharge results

Sample Date	15-Feb-2022	17-May-2022	23-Aug-2022	26-Nov-2022
TSS Result (mg/L)	<3.0	63.9	19	<3.0



3.8 Lead Sampling

In accordance with Schedule 15.1 (Lead) of O. Reg. 170/03, a *Corrosion Control Plan* for the Hudson DWS was required to be developed in 2011 following unfavourable results associated with the community lead sampling program. The selected corrosion control measure involves maintaining treated water pH at a value of 7.8 +/- 0.2 units using a sodium hydroxide chemical feed system. Corrosion control has been effective, and data suggest that reductions in both the average and 90th percentile lead concentrations are between 80% to 85%. The ODWQS sample exceedance rate has also been reduced from 16.4% to 3.3%.

The system now adheres to the lead monitoring program outlined in its *Municipal Drinking Water Licence*, which requires the collection of distribution and plumbing samples on an annual basis. Table 12 summarizes the results of community lead sampling conducted in 2022. All distribution and plumbing samples were collected October 3, 2022. One plumbing sample was above the limit for lead. A notice of Lead Exceedance Test Results in Plumbing was completed.

Table 12: Lead sampling results summary

Sample Type	No. of Sample Points	No. of Samples	Min. Result (µg/L)	Max. Result (µg/L)	ODWQS (µg/L)	No. of Sample Point Exceedances	No. of Sample Exceedances
Treated	1	2	<1.0	<1.0	10	0	0
Distribution	2	2	<1.0			0	0
Plumbing ¹	5	10	<1.0	10.7		1	1

1. In accordance with the protocol outlined in Schedule 15.1 of O. Reg. 170/03, two samples are collected and analyzed for lead at each sample point for plumbing samples.

3.9 Inorganic & Organic Parameters

Most inorganic parameters are sampled on an annual basis in treated water in accordance with Schedules 13 (Chemical sampling and testing) and 23 (Inorganic parameters) of O. Reg. 170/03. The inorganic parameters sodium and fluoride are sampled every five (5) years in treated water in accordance with Schedules 13 and 23 of O. Reg. 170/03. The most recent inorganic parameter sampling results are provided in Table 13. All results were below the associated Ontario Drinking Water Quality Standards.

Table 13: Inorganic parameter sampling results

Parameter	Most Recent Sample Date	Units	Result	ODWQS
Antimony	16-Aug-2022	µg/L	<0.60	6
Arsenic	16-Aug-2022	µg/L	<1.0	10
Barium	16-Aug-2022	µg/L	<10	1000
Boron	16-Aug-2022	µg/L	<50	5000
Cadmium	16-Aug-2022	µg/L	<0.10	5
Chromium	16-Aug-2022	µg/L	<1.0	50
Fluoride	25-Feb-2020	mg/L	<0.020	1.5
Mercury	16-Aug-2022	µg/L	<0.10	1
Selenium	16-Aug-2022	µg/L	<1.0	50
Sodium	25-Feb-2020	mg/L	9.34	20
Uranium	16-Aug-2022	µg/L	<2.0	20

Organic parameters are sampled on an annual basis in treated water in accordance with Schedules 13 (Chemical sampling and testing) and 24 (Organic parameters) of O. Reg. 170/03. These parameters include various organic acids, pesticides, herbicides, PCBs, volatile organics and other chemicals. Sampling for all organic parameters except total PCBs was conducted on August 16, 2022. Sampling results are provided in Table 14; all results were below the associated Ontario Drinking Water Quality Standards.

Table 14: Organic parameter sampling results

Parameter	Result (µg/L)	ODWQS (µg/L)	Parameter	Result (µg/L)	ODWQS (µg/L)
Alachlor	<0.10	5	Diuron	<1.0	150
Atrazine & Metabolites	<0.20	5	Glyphosate	<5.0	280
Azinphos-methyl	<0.10	20	Malathion	<0.10	190
Benzene	<0.50	1	MCPA	<0.20	100
Benzo(a)pyrene	<0.005	0.01	Metolachlor	<0.10	50
Bromoxynil	<0.20	5	Metribuzin	<0.10	80
Carbaryl	<0.20	90	Monochlorobenzene	<0.50	80
Carbofuran	<0.20	90	Paraquat	<1.0	10
Carbon Tetrachloride	<0.20	2	Pentachlorophenol	<0.50	60
Chlorpyrifos	<0.10	90	Phorate	<0.10	2
Diazinon	<0.10	20	Picloram	<0.20	190
Dicamba	<0.20	120	Total PCBs	<0.035	3
1,2-Dichlorobenzene	<0.50	200	Prometryne	<0.10	1
1,4-Dichlorobenzene	<0.50	5	Simazine	<0.10	10
1,2-Dichloroethane	<0.50	5	Terbufos	<0.20	1
1,1-Dichloroethylene	<0.50	14	Tetrachloroethylene	<0.50	10
Dichloromethane	<5.0	50	2,3,4,6-Tetrachlorophenol	<0.50	100
2,4-Dichlorophenol	<0.30	900	Triallate	<0.10	230
2,4-D	<0.20	100	Trichloroethylene	<0.50	5
Diclofop-methyl	<0.20	9	2,4,6-Trichlorophenol	<0.50	5
Dimethoate	<0.10	20	Trifluralin	<0.10	45
Diquat	<1.0	70	Vinyl Chloride	<0.20	1

3.10 Harmful Algae Bloom Monitoring

Starting in 2022 a requirement was added to the Municipal Drinking Water License to monitor for Harmful Algae Blooms. If a bloom is identified or suspected, then microcystin testing must be undertaken. According to the HAB plan sampling must continue for three (3) weeks of no microcystin identified. There was one (1) suspected bloom in 2022. Testing results shown in Table 15 did not identify any microcystin. The sample from September 20, 2022 was not completed by the lab but notification was not received until after the end of sampling requirements.

Table 15: Microcystin results						
Sample Date	6-Sep-2022		13-Sep-2022		20-Sep-2022	
Microcystin (µg/L)	Raw	Treated	Raw	Treated	Raw	Treated
	<0.1	<0.1	<0.1	<0.1	NR	NR

4 Water Production

4.1 Overview

In accordance with Schedule 22 (Summary Reports for Municipalities) of O. Reg. 170/03, this Annual Report must include certain information for the purpose of enabling the Owner to assess the capability of the system to meet existing and planned uses. Specifically, this Report must include a summary of the quantities and flow rates of the water supplied during the reporting period, including monthly average and maximum daily flows. The Report must also include a comparison of flow monitoring results to the rated capacity and flow rates approved in the system's *Municipal Drinking Water Licence*.

4.2 Flow Monitoring Results

Throughout the reporting period the Hudson Drinking Water System operated within its rated capacity and supplied a total of 33,947 m³ of treated water. On an average day in 2022, 93 m³ of treated water was supplied to the community, which represents 13% of the rated capacity of the Hudson Water Treatment Plant (726 m³/day). The maximum daily flow in 2022 was 179 m³/day, which represents 25% of the rated capacity of the treatment facility. Flow monitoring results are summarized in Figure 1 and Table 15. The capacity assessments in the table compare the average and maximum daily flows to the rated capacity of the treatment facility.

Figure 1: 2022 average and maximum daily treated water flows




Table 16: 2022 Water production summary

Month	Total Volumes (m³)		Daily Flows (m³/day)		Capacity Assessments	
	Raw Water	Treated Water	Average - Treated	Maximum - Treated	Average - Treated	Maximum - Treated
Jan	3,546	3,425	110	127	15%	17%
Feb	2,076	2,013	72	85	10%	12%
Mar	2,655	2,556	82	95	11%	13%
Apr	3,042	2,950	98	108	14%	15%
May	3,909	3,754	121	141	17%	19%
Jun	3,613	3,411	114	179	16%	25%
Jul	3,097	2,914	94	166	13%	23%
Aug	3,029	2,791	90	136	12%	19%
Sep	2,804	2,649	88	171	12%	24%
Oct	2,332	2,165	70	159	10%	22%
Nov	2,120	1,980	66	108	9%	15%
Dec	3,541	3,339	108	131	15%	18%
Total	35,764	33,947	---	---	---	---
Average	2,980	2,829	93	---	13%	---

4.3 Recent Historical Flows

Table 16 summarizes recent historical flow monitoring results for the Hudson Drinking Water System. There was an increase in the volumes of source water withdrawn and treated water supplied in 2022 when compared to 2021. Total annual volumes of treated water supplied in the near future may be expected to be between 15,000 m³ and 40,000 m³, which represents approximately 6% to 15% of the rated capacity of the Hudson Water Treatment Plant.

Table 17: Recent historical water production summary

Year	Total Volumes (m ³)		Daily Flows (m ³ /day)		Annual % Change	
	Raw Water	Treated Water	Average – Treated	Maximum – Treated	Raw Water	Treated Water
2011	52,922	45,980	126	238	+23.2%	+22.7%
2012	33,668	25,760	70	236	-36.4%	-44.0%
2013	28,380	20,642	57	136	-15.7%	-19.9%
2014	32,466	24,077	66	202	+14.4%	+16.6%
2015	29,321	22,501	62	157	-9.7%	-6.5%
2016	27,326	21,186	58	119	-6.8%	-5.8%
2017	37,731	32,219	88	208	+38.1%	+52.1%
2018	28,237	26,006	71	196	-25.2%	-19.3%
2019	26,557	24,668	68	183	-6.0%	-5.1%
2020	32,642	30,521	83	168	+22.9%	+23.7%
2021	32,380	31,079	85	319	-0.8%	+1.8%
2022	35,763	33,947	93	179	10.4%	9.2%


5 Compliance

5.1 Overview

Northern Waterworks Inc. and the Municipality of Sioux Lookout employ an operational strategy that is committed to achieving the following goals:

- Providing a safe and reliable supply of drinking water to the community of Hudson;
- Meeting or exceeding all applicable legislative and regulatory requirements; and,
- Maintaining and continually improving the operation and maintenance of the system.

The following sections will summarize incidents of adverse water quality and regulatory noncompliance that occurred during the reporting period. NWI is committed to employing timely and effective corrective actions to prevent recurrence of all identified incidents of adverse water quality and regulatory noncompliance.



5.2 Regulatory Compliance

In accordance with Schedule 22 (Summary Reports for Municipalities) of O. Reg. 170/03, this Report must list any requirements of the *Act*, the regulations, the system's approval, drinking water works permit, municipal drinking water licence, and any orders applicable to the system that were not met at any time during the period covered by the report (i.e., an incident of regulatory noncompliance). Additionally, this Report must specify the duration of the failure and the measures that were taken to correct the failure.

The most recent inspection by Ontario's Ministry of the Environment, Conservation and Parks was initiated on June 16, 2022. The final inspection rating was 100% and no incidents of regulatory noncompliance were identified.

5.3 Adverse Water Quality Incidents

In accordance with section 11 (Annual Reports) of O. Reg. 170/03, this Report must summarize any reports made to the Ministry under subsection 18(1) (Duty to report adverse test results) of *the Act* or section 16-4 (Duty to report other observations) of Schedule 16 of O. Reg. 170/03. Additionally, this Report must describe any corrective actions taken under Schedule 17 of O. Reg. 170/03 during the period covered by the report.

The one (1) adverse water quality incident that occurred during the reporting period is summarized below.

- **AWQI No. 160842 (November 29, 2022)**
Filtered water produced from 11:45 to 13:34 bypassed the UV disinfection chamber. Corrective action was performed in accordance with O. Reg. 170/03 and included collecting bacteriological samples. CT calculations were run using only chlorine residuals which indicated that the required disinfection had been achieved without the UV. All the bacteriological samples had showed non-detect. Contractors will be onsite to recommend changes to the system to help prevent reoccurrence